



HEATING/COOLING

- Results for reverse-cycle based space conditioning only (n=7)
- Relatively small demand, longer heating season
- Annual mean 3907MJ, SD 230MJ, coefficient of variation of 0.059
- No distinguishable pattern of energy use rebound
- Demand impacted by combination of solar and temperature